



Information for Designers

Local Design Criteria for Pulaski County

This information is provided for use by builders and designers and is in accordance with the 2018 editions of the Virginia USBC, the International Building Code, and the International Residential Code.

Residential 1 & 2 Family Construction Design Parameters

Ground Snow Load	Wind Speed MPH V ^{3s}	Seismic Design Category	Subject to Damage From				Winter Design Temp	Ice Shield Req?	Flood Hazards
			Weathering	Frost Depth	Termite	Decay			
25 psf	115	B	Severe	24"	Moderate-Heavy	Slight-Moderate	16°F	Yes	FEMA Map

Commercial Construction Design Parameters

Ground Snow Load	Wind Speed MPH V _{3s}	Spectral Response Acceleration		Frost Depth	Weathering
		S _s %g	S ₁ %g		
25 psf	115	28%	8%	24"	Severe

Additional Design Information

Current Code Editions

2021 VA Uniform Statewide Building Code Effective 1/18/2025

Referenced Codes:

- 2021 International Building Code
- 2021 International Plumbing Code
- 2021 International Mechanical Code
- 2021 International Fuel Gas Code
- 2021 International Energy Conservation Code
- 2021 International Residential Code
- 2021 International Existing Building Code
- 2017 ANSI A117.1 Accessible & Usable Buildings & Facilities
- 2019 NFPA 13 Standard for the Installation of Sprinklers
- 2019 NFPA 72 National Fire Alarm Code
- 2020 NFPA 70 National Electrical Code

Contact Information

Scott Macdonald, CBO
 Pulaski County Building Official
 143 3rd Street, NW
 Pulaski, VA 24301
 Office (540)980-7710
 Fax (540)980-7717